

A D D E N D U M N O . 2

**DETENTION CELLS/DISPATCH RELOCATION
ROCKY HILL POLICE DEPARTMENT**

Rocky Hill, CT
KBA #15068.00 – **BID NO. 2016-007**

Date: May 6, 2016

Page: 1 of 1

The following changes to the Project Manual shall become a part of the Drawings, Specifications, Bidding Requirements and Contract Documents; superseding previously issued Drawings, Specifications, Bidding Requirements, Contract Documents and Addenda, to the extent modified by this Addendum.

ATTACHMENTS

Bid Questions and Responses: RRFI 006

J.A. Rosa Construction, LLC

REQUEST FOR INFORMATION

Project: Rocky Hill Police Department
Architect: Kaestle Boos Associates
Date: May 6, 2016
Drawing No.: A1.01A
Specification: N/A

Description:

Please provide a flooring type for therapy room 204 and lobby 200.

THE THERAPY ROOM 204 FLOORING SHALL BE CARPET TILE PER SPECIFICATION 096813 WITH VINYL WALL BASE. THE LOBBY 200 FLOOR FINISH IS EXISTING TO REMAIN, PROVIDE TRANSITION STRIPS BETWEEN NEW FINISHES AND EXISTING.